

# SCHNEIDER LABORATORIES INCORPORATED

2512 W. Cary Street • Richmond, Virginia • 23220-5117  
804-353-6778 • 800-785-LABS (5227) • (FAX) 804-353-6928

*Excellence in Service and Technology*

AIHA/ELLAP 100527, NVLAP 101150-0, NYELAP/NELAC 11413, CAELAP 2078, NC 593

## LABORATORY ANALYSIS REPORT

Lead Analysis by EPA 3050B/7420 Method

**ACCOUNT #:** 500-03-468  
**CLIENT:** SCHNEIDER LABORATORIES, INC.  
**ADDRESS:** 2512 W. CARY STREET  
RICHMOND, VA 23220-5117

**DATE COLLECTED:** 4/ 1/2003  
**DATE RECEIVED:** 4/ 3/2003  
**DATE ANALYZED:** 4/ 3/2003  
**DATE REPORTED:** 4/ 3/2003

**PO NO.:** 134679  
**PROJECT NAME:** Lead Control  
**PROJECT NO.:** 3537247  
**JOB LOCATION:** 1634 Broad St

**SAMPLE TYPE:** PAINT

| SLI<br>Sample<br>No. | Client<br>Sample<br>No. | Sample<br>Description | Sample<br>Wt<br>(mg) | Dilution<br>Factor | Total<br>Lead<br>(µg)* | Lead<br>Conc<br>(% by wt) |
|----------------------|-------------------------|-----------------------|----------------------|--------------------|------------------------|---------------------------|
| 2616658              | 1                       | Living Rm Wall A      | 532                  | 2                  | 339.5                  | 0.064                     |
| 2616659              | 2                       | Living Rm Wall B      | 558                  | 1                  | 54.0                   | 0.010                     |
| 2616660              | 3                       | Bath Rm Wall A        | 463                  | 100                | 55,243.7               | 11.932                    |
| 2616661              | 4                       | Bath Rm Wall B        | 589                  | 1                  | < 20.0                 | < 0.003                   |
| 2616662              | 5                       | BR Wall A             | 488                  | 20                 | 5,517.4                | 1.131                     |
| 2616663              | 6                       | BR Wall B             | 552                  | 10                 | 8,032.7                | 1.455                     |

Analysis Run ID: 25759

**ANALYST: DEREK L. JACKSON**

Total no. of pages in report =

**REVIEWED BY** Matthew D. Asbury, Dept. Head

*Minimum Reporting Limit: 20 µg Total Lead. For work involving HUD, child-occupied building and other residential units, the Federal Lead Standard is 0.5% lead by weight [5000 ppm]. The requirements of the OSHA Lead in Construction Standard, 29 CFR 1926.62, are invoked if any lead is present in the sample; there is no minimum concentration. Lead-free paint is defined as <0.06% by weight (CPSC). \*For true values, assume two (2) significant figures. All testing is performed in strict accordance with Schneider Laboratories, Inc. protocol.*