



Customer:

Address:

**Order #:** 103824

**Matrix** Paint  
**Received** 12/05/13  
**Analyzed** 12/05/13  
**Reported** 09/24/14

Attn:

Project:

Location:

Number:

**PO Number:**

Sample ID	Cust. Sample ID	Location	Sample Date	Weight			
Parameter		Method		Total µg	Conc. % by Wt.	RL	Conc.
<b>103824-002</b>	2	Brown Wood Fascia Board	12/03/13	329 mg			
Lead		EPA 7000B / 3050B		<10.0 µg	<0.00304 %	30.4 mg/kg	<30.4 mg/kg
<b>103824-003</b>	3	Lower Wood Fascia Dark Brown	12/03/13	328 mg			
Lead		EPA 7000B / 3050B		13.0 µg	0.00396 %	30.5 mg/kg	39.6 mg/kg
<b>103824-004</b>	4	Downspout/Gutter Cream	12/03/13	233 mg			
Lead		EPA 7000B / 3050B		<10.0 µg	<0.00429 %	42.9 mg/kg	<42.9 mg/kg
<b>103824-005</b>	5	Downspout/Gutter Cream	12/03/13	329 mg			
Lead		EPA 7000B / 3050B		37.0 µg	0.0112 %	30.4 mg/kg	112 mg/kg

Analyst: SA

103824-09/24/14 02:41 PM

Reviewed By:

Minimum reporting limit: 10.0 µg. Lead Based Paint contains 0.5% lead by weight per Federal statute. The OSHA Lead in Construction Standard, 29 CFR 1926.62, is invoked if any lead is present in the sample. Concentration and Reporting Limit (RL) based on weights provided by client. All internal QC parameters were met. Unusual sample conditions, if any, are described. Values are reported to three significant figures. PPM = mg/kg | PPB = µg/kg. The analysis data reported relates only to the samples as submitted.