



Customer:

Address:

Received 09/07/18
Analyzed 09/14/18
Reported 09/28/18

Project:

Location:

Number:

Method: EPA 600/R-93/116 & 600/M4-82-020

PLM Analysis

| Sample ID | Collected | Cust. ID | Location | Asbestos Fibers | Other Materials |
|-------------------|--------------------------|----------|-------------|-----------------|--------------------------|
| 278325-001 | 09/05/18 | 1 | Living Room | | |
| Layer 1: | Tile | | | 3% CHRYSOTILE | 97% NON FIBROUS MATERIAL |
| | Brown, Organically Bound | | | | |
| Layer 2: | Mastic | | | None Detected | 2% CELLULOSE FIBER |
| | Black, Bituminous | | | | 98% NON FIBROUS MATERIAL |
| 278325-002 | 09/05/18 | 2 | Bedroom #2 | | |
| Layer 1: | Tile | | | 2% CHRYSOTILE | 98% NON FIBROUS MATERIAL |
| | Beige, Organically Bound | | | | |
| Layer 2: | Mastic | | | None Detected | 2% CELLULOSE FIBER |
| | Clear, Soft | | | | 98% NON FIBROUS MATERIAL |
| 278325-003 | 09/05/18 | 3 | Bedroom #3 | | |
| Layer 1: | Tile | | | 3% CHRYSOTILE | 97% NON FIBROUS MATERIAL |
| | Beige, Organically Bound | | | | |
| Layer 2: | Mastic | | | None Detected | 2% CELLULOSE FIBER |
| | Clear, Soft | | | | 98% NON FIBROUS MATERIAL |

EPA Regulatory Limit: 1%

Total layers analyzed on order: 6

278325-09/28/18 03:36 PM

Reviewed By: _____

Reporting Limit: 1% Gravimetrically Reduced Reporting Limit: 0.01% PLM analysis is based on Visual Estimation and NESHAP recommends that any asbestos content less than 10 percent be verified by PLM Point Count or TEM Analysis. The EPA recommends that any vermiculite should be treated as Asbestos Containing Material (ACM). This report must not be reproduced except in full with the approval of the laboratory. The test results reported relate only to the samples submitted.