



Customer:

Address:

Order #:

111210

Matrix

Drinking Water

Received

09/22/14

Reported

09/23/14

PO Number:

Attn:

Project:

Location:

Number:

| Sample ID                    | Cust. Sample ID | Location | Result  | RL*  | Units     | Analysis Date | Analyst |
|------------------------------|-----------------|----------|---------|------|-----------|---------------|---------|
| Parameter                    |                 | Method   |         |      |           |               |         |
| 111210-001                   | 1               |          |         |      |           |               |         |
| <b>Microbiology Analysis</b> |                 |          |         |      |           |               |         |
| E. coli (MPN)                |                 | SM 9223B | <1.00   | 1.00 | MPN/100ml | 09/24/14      | JDW     |
| E. coli (P/A)                |                 | SM 9223B | Absent  |      |           | 09/24/14      | JDW     |
| Total Coliform (MPN)         |                 | SM 9223B | 61.3    | 1.00 | MPN/100ml | 09/24/14      | JDW     |
| Total Coliform (P/A)         |                 | SM 9223B | Present |      |           | 09/24/14      | JDW     |

111210-09/23/14 12:52 PM

### Collection and Analysis Times

for tests with under 48 hour EPA Holding Times

Reviewed By:

| Sample                 | Collection           |
|------------------------|----------------------|
| 111210-001             | 9/22/2014 3:21:00 PM |
| Test                   | Analysis             |
| Total Coliform P/A MPN | 9/24/2014            |
| E. coli P/A MPN        | 9/24/2014            |

### EPA Regulatory Limits

| Parameter            | Reg. Limit | Unit      |
|----------------------|------------|-----------|
| E. coli (MPN)        | <1.00      | MPN/100ml |
| E. coli (P/A)        | Absent     | N/A       |
| Total Coliform (P/A) | Absent     | N/A       |

### State Certifications

| Method   | Parameter            | Virginia      |
|----------|----------------------|---------------|
| SM 9223B | E. coli (MPN)        | Not Certified |
| SM 9223B | E. coli (P/A)        | Not Certified |
| SM 9223B | Total Coliform (MPN) | Not Certified |
| SM 9223B | Total Coliform (P/A) | Not Certified |

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.