



Customer:

Address:

Order #: 110873

Matrix Drinking Water

Received 09/16/14

Reported 09/17/14

Attn:

Project:

Location:

Number:

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
110873-001	1	1st Flr Front Kitchen Flush					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	09/16/14	SA
110873-002	2	1st Flr Rear Kitchen Flush					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	09/16/14	SA
110873-003	3	2nd Flr Kitchen Flush					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	09/16/14	SA

110873-09/17/14 02:31 PM

Reviewed By: _____

EPA Regulatory Limits

Parameter	Reg. Limit	Unit
Lead	15.0	µg/L

State Certifications

Method	Parameter	Rhode Island	Virginia
EPA 200.9 Rev 2.2	Lead	RIDOH Certified	VELAP Certified

State	Certificate Number
Rhode Island	RIDOH LAO00084
Virginia	VELAP 5437

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.