



Customer:

Address:

Order #: 253833

Matrix Air
Received 03/29/18
Analyzed 03/30/18
Reported 03/30/18

PO Number:

Attn:

Project:

Location:

Number:

Method NIOSH 7400 Issue 2 Aug. 15 1994

Sample ID	Cust. ID	Location	Date	Time	Vol.	Fibers (f/field)	Density (f/mm ²)	Exposure (f/cc)
253833-001			03/29/18	135 min	1350 L	0.0650	8.28	0.00236
253833-002			03/29/18	135 min	1350 L	<0.0550	<7.01	<0.00200
253833-003			03/29/18	135 min	1350 L	0.0700	8.92	0.00254
253833-004			03/29/18	135 min	1350 L	<0.0550	<7.01	<0.00200
253833-005			03/29/18	135 min	1350 L	0.0650	8.28	0.00236

Analyst:

253833-03/30/18 12:20 PM

Reviewed By:

Laboratory Sr

Range	Sr
5 - 20	0.459
20.5 - 50	0.215
50.5 - 500	0.237

Area Samples. OSHA Asbestos PEL is 0.1 f/cc for 8 hour TWA. Est. limit of detection: 7 f/mm² or 0.055 f/field. (<) refers to less than limit of detection. Results are not blank-corrected unless noted by analyst. Exposure and TWA calculations are based on client-supplied air volumes and times, and assume zero exposure for time not sampled. Analyst relative standard deviation (Sr) calculated using historical data. Calculated values are reported to three significant figures. The test results reported relate only to the samples submitted. NY Samples fall under NY Certificate #11413